

Allegheeny County Health Department

RECEIVED SEP 24 1993

COUNTY COMMISSIONERS

Tom Foerster
Chairman

Pete Flaherty

Larry Dunn

Bruce W. Dixon, M.D.
Director



Plumbing Section
3901 Penn Avenue
Pittsburgh, PA 15224-1345
(412) 578-8375

BOARD OF HEALTH

Roy L. Titchworth, M.D.
Chairman

Martin Krauss, O.D.
Vice Chairman

Robert Engel, Esq.
Susanne M. Gollin, Ph.D.
Azizi Powell

Msgr. Charles Owen Rice
Frederick Ruben, M.D.

Anthony D. Stagno, Sr.
Katherine L. Wisner, M.D., M.S.

September 21, 1993

Topp Industries, Inc
P.O. Box 420
Highway 25 North
Rochester, TN 46975

Attn Steve Keiser
Re: Request Appeal - Polyethylene and Fiberglass Sump/Easins
Residential and Commercial application

Dear Mr. Keiser:

This will confirm your request to the Allegheny County Plumbing Board of Appeals relative to the above mentioned appeal.

This is to advise you the Plumbing Board acting on the recommendation of the Appeals Committee, approved your request for Code acceptance of your subject.

This sump will be acceptable for sanitary and storm drainage in residential and commercial dwellings. When installed for sanitary drainage, they must have gas and air tight lids; and must be installed in accordance with manufacturers recommendation and code requirements.

This approval was granted at the Plumbing Board meeting of Wednesday, September 15, 1993 and is based upon an evaluation of the material and standards as submitted to the Board.

Any change in basic materials may void such approval, when, in the opinion of the Board, such change alters the design or quality of the material.

This letter is not to be used for advertising purposes, but may be used to indicate approval by this Plumbing Board.

Sincerely,

James J. O'Donnell
James J. O'Donnell
Secretary
Plumbing Advisory Board

JJO/fab
PC: Board Chairman
Appeals Committee